



2024 **Annual** **Summary** **Report**

The Corporation of the Township of Cramahe

Colborne Drinking Water System

Prepared by: Lakefront Utility Services Inc.



CONTENTS

| | | |
|-----------|--|----------|
| 1. | PURPOSE | 3 |
| 2. | COLBORNE DRINKING WATER SYSTEM OVERVIEW | 4 |
| 3. | 2024 COMPLIANCE | 4 |
| 3.1 | MECP Inspection | 4 |
| 3.2 | License & Permit Compliance | 4 |
| 3.3 | Adverse Water Quality Incident(s)..... | 7 |
| 4. | CONTINUAL IMPROVEMENT | 7 |
| 5. | SAMPLING AND ANALYSIS | 8 |

1. PURPOSE

The purpose of the Annual Water Quality Report is to provide information to residents and stakeholders of the Township of Cramahe. Furthermore, satisfying the regulatory requirements of the *Safe Drinking Water Act, 2002* including the Drinking Water Quality Management Standard (DWQMS) reports to owner, and regulatory reporting required under *Ontario Regulation 170/03*. This annual water quality report fulfills all requirements of *Ontario Regulation 170/03* Section 11 Annual Reports and Schedule 22 Summary Reports for Municipalities.

The annual water quality report is prepared by Lakefront Utility Services Inc. (operating authority) on behalf of the Township of Cramahe (owner).

Scope

This annual water quality report includes information pertaining to the Village of Colborne's Drinking Water System (Colborne DWS) for the period of January 1, 2024 to December 31, 2024. *Ontario Regulation 170/03* requires reported information be provided to:

- **Drinking Water System Owners (Mayor and Council)**
- **Owner and Operating Authority Top Management**
- **The Public**

Availability

The Colborne DWS is a large municipal residential system that serves approximately 2,000 people. Copies of this annual water quality report are available online at <https://www.lakefrontutilities.com/regulatory-water/>. Hard copies are also available at the LUSI's office at 207 Division St, Cobourg ON, K9A 4L3.

Customers of the Colborne DWS are notified that the annual water quality report is available via "What's New" <https://www.lakefrontutilities.com/whats-new/>, social media posts and "Stay Connected" LUSI bill insert.

Council Resolution

Ontario Regulation 170/03 requires Summary Reports be distributed to municipal council no later than March 31 of each year. The Township of Cramahe must provide LUSI with a copy of council resolution indicating the report has been accepted.

2. COLBORNE DRINKING WATER SYSTEM OVERVIEW

The Colborne Water Treatment Plant (WTP) takes water from two wells, Well #1a and Well #2, located approximately 25m apart from each other. *Sodium hypochlorite* is injected for disinfection and *sodium silicate* is used as an iron sequestering agent. Primary disinfection is achieved via the 215m serpentine (buried east of the plant). Water is conveyed to the distribution system and the elevated storage tank, which has a capacity of 2,342m³.

The distribution system is split into two pressure zones that are regulated by two pressure reducing valves that maintain the pressure between 20 and 90 PSI. There are a total of 1028 metered customers. Water is conveyed to customers by approximately 27 km of watermain ranging from 25 mm to 250 mm, made of PVC, ductile iron and cast iron. There are 138 fire hydrants located within the system.

3. 2024 COMPLIANCE

3.1 MECP INSPECTION

The Colborne Drinking Water System underwent an announced focused MECP compliance inspection starting May 14, 2024 and achieved an inspection rating of 100%. This was a vast improvement from the previous inspection where the inspection rating was 87.98%. There was one best management practices recommendation.

3.1.1. Best Management Practice

- At the time of inspection there were no measures to promote water conservation. The Township provided a newsletter to residents in 2024 and will work on developing further measures to promote water conservation.


3.2 LICENSE & PERMIT COMPLIANCE

The Colborne DWS maintained compliance with all applicable legislation, and all terms and conditions of the Municipal Drinking Water License (138-101, Issue 4, November 5, 2021), Drinking Water Works Permit (138-201, Issue 3, November 5, 2021), and Permit to Take Water (Permit No. 8612-BNENBH, April, 2020) in 2024.

The Colborne DWS Permit to Take Water allows the taking of 3,283.2 m³ of water from each well per day at a rate of 2,280 L/min. The average flow rate from the production wells was 787 L/min.

The total quantity of water taken and discharged from the WTP is illustrated in Figure 1, Table 1 and Table 2. In September 2024, the WTP operated at 39.5% of its maximum rated capacity, as shown in Figure 2. The labels presented in Figure 2 are representative of the maximum flow observed for the respective month (m³).

Figure 1 - Flow Quantities Colborne Drinking Water System






Table 1 - Raw Water Flows (m3)

| Month | Monthly Total | Monthly Total Well 1a | Monthly Total Well 2 | Daily Average | Minimum | Maximum | % Max PTTW |
|----------------|----------------|-----------------------|----------------------|---------------|------------|--------------|--------------|
| January | 20,779 | 8,424 | 12,355 | 670 | 232 | 1,125 | 34.7% |
| February | 18,678 | 93 | 18,586 | 644 | 379 | 852 | 26.3% |
| March | 19,450 | 143 | 19,306 | 627 | 205 | 965 | 29.8% |
| April | 22,641 | 164 | 22,477 | 755 | 413 | 1,218 | 37.6% |
| May | 23,163 | 110 | 23,053 | 747 | 320 | 1,243 | 38.4% |
| June | 23,034 | 118 | 22,916 | 768 | 395 | 1,107 | 34.2% |
| July | 24,664 | 86 | 24,578 | 796 | 508 | 1,214 | 37.5% |
| August | 24,971 | 109 | 24,863 | 806 | 382 | 1,097 | 33.9% |
| September | 22,810 | 83 | 22,727 | 760 | 462 | 1,278 | 39.5% |
| October | 21,766 | 62 | 21,703 | 702 | 419 | 1,095 | 33.8% |
| November | 17,961 | 74 | 17,887 | 599 | 262 | 1,052 | 32.5% |
| December | 18,366 | 88 | 18,278 | 592 | 325 | 1,039 | 32.1% |
| Total | 258,283 | 9,554 | 248,729 | - | - | - | - |
| Average | 21,524 | 796 | 20,727 | 706 | 205 | 1,278 | 39.5% |

Table 2 - Treated Water Flows (m3)

| Month | Monthly Total | Daily Average | Daily Maximum | Daily Minimum |
|----------------|----------------|---------------|---------------|---------------|
| January | 20,779 | 670 | 1,125 | 323 |
| February | 18,678 | 644 | 852 | 379 |
| March | 19,450 | 623 | 965 | 205 |
| April | 22,641 | 752 | 1,218 | 413 |
| May | 23,163 | 744 | 1,243 | 320 |
| June | 23,034 | 764 | 1,107 | 395 |
| July | 24,664 | 793 | 1,198 | 508 |
| August | 24,971 | 802 | 1,097 | 382 |
| September | 22,810 | 758 | 1,278 | 462 |
| October | 21,766 | 700 | 1,084 | 419 |
| November | 17,961 | 596 | 1,033 | 262 |
| December | 18,366 | 590 | 1,039 | 325 |
| Total | 257,312 | - | - | - |
| Average | 21,443 | 703 | 1,278 | 205 |

3.3 ADVERSE WATER QUALITY INCIDENT(S)

There were no adverse water quality incidents in 2024.

4. CONTINUAL IMPROVEMENT

LUSI's commitment to continual improvement requires investigating and investing in, where appropriate, methods and technologies to improve

- The quality of processes used to ensure production of ample clean water, and
- The quality and effectiveness of the distribution system.

During the 2024 reporting year, LUSI demonstrated this commitment by completing all the activities listed in Table 1. Table 1 also satisfies O. Reg 170/03 requirement to describe major expenses occurred during the reporting period.

Table 1 - 2024 Major Expenses Incurred at the Colborne WTP, Distribution System and Misc. Activities

| | | |
|-------------------------|---------------------|-----------|
| Colborne DWS | Meter Replacement | \$221,000 |
| | Old Percy Watermain | \$6,381 |
| | MCC/SCADA Upgrades | \$36,691 |

5. SAMPLING AND ANALYSIS

The Colborne DWS exhibited compliance with all sampling and testing as required by *Ontario Regulation 170/03* in the 2023 calendar year. Table 2 illustrates all microbiological testing done under Schedule 10 of *Ontario Regulation 170/03*. There were no instances of adverse water quality results as a result of a parameter exceeding its respective maximum acceptable concentration.

Table 2 – Colborne DWS Microbiological Sampling

| | E. Coli, (cfu/100mL) | | Total Coliform, (cfu/100mL) | | HPC, (cfu/1mL) | |
|---------------------|-----------------------------|----------------------------------|------------------------------------|----------------------------------|-----------------------|----------------------------------|
| | # of Samples | Range of Results (min # - max #) | # of Samples | Range of Results (min # - max #) | # of Samples | Range of Results (min # - max #) |
| Raw Well 1a | 53 | 0 - 0 | 53 | 0 - 0 | 0 | N/A |
| Raw Well 2 | 53 | 0 - 0 | 53 | 0 - 0 | 0 | N/A |
| Treated | 53 | 0 - 0 | 53 | 0 - 0 | 53 | 0 - 4 |
| Distribution | 159 | 0 - 0 | 159 | 0 - 0 | 102 | 0 - 23 |

Operational testing done under Schedule 7 of Ontario Regulation 170/03 during the 2023 reporting period are tabulated in Table 3.

Table 3 – Colborne DWS Schedule 7 Operational Monitoring Samples

| | Number of Grab Samples | Range of Results (min # - max #) |
|--|------------------------------|----------------------------------|
| Turbidity, Raw Water Well 1a (NTU) | 12 | 0.29-0.86 |
| Turbidity, Raw Water Well 2 (NTU) | 12 | 0.22-0.60 |
| Turbidity, Treated Water (NTU) | 12 | 0.11-0.62 |
| Treated Water Free Chlorine Residual (mg/L) | 8760 (continuous monitoring) | 0 – 5.0 |

In addition to the microbiological sampling and testing requirements, sampling and testing is required for chemical, inorganic and organic parameters. Table 4 illustrates Schedule 13, Schedule 23 and Schedule 24 sample analysis results, with no exceedances during the reporting period. If there were multiple samples taken during the reporting period, the most recent sample result is provided. A parameter below the

method detection limit indicated by (<) or an ND, cannot be detected as the concentration is lower than minimum concentration that can be measured and reported with 99% certainty.

Table 4 – Colborne DWS Schedule 13, 23 and 24 Sampling

| PARAMETER | STANDARD (µg/L) | SAMPLE RESULT (µg/L) | SAMPLE DATE |
|--|--------------------|-------------------------|-------------|
| Antimony | 6 | 0.6 <MDL | 8-Jan-24 |
| Arsenic | 10 | 1 | |
| Barium | 1000 | 145 | |
| Boron | 5000 | 6 | |
| Cadmium | 5 | 0.004 | |
| Chromium | 50 | 0.09 | |
| Mercury | 1 | 0.01 <MDL | |
| Selenium | 50 | 0.08 | |
| Uranium | 20 | 7.49 | |
| Benzene | 1 | 0.32 <MDL | |
| Carbon tetrachloride | 2 | 0.17 <MDL | |
| 1,2-Dichlorobenzene | 200 | 0.41 <MDL | |
| 1,4-Dichlorobenzene | 5 | 0.36 <MDL | |
| 1,1-Dichloroethylene (vinylidene chloride) | 14 | 0.33 <MDL | |
| 1,2-Dichloroethane | 5 | 0.35 <MDL | |
| Dichloromethane | 50 | 0.35 <MDL | |
| Monochlorobenzene | 80 | 0.3 <MDL | |
| Tetrachloroethylene (perchloroethylene) | 10 | 0.35 <MDL | |
| Trichloroethylene | 5 | 0.44 <MDL | |
| Vinyl Chloride | 1 | 0.17 <MDL | |
| Diquat | 70 | 1 <MDL | |
| Paraquat | 10 | 1 <MDL | |
| Glyphosate | 280 | 1 <MDL | |
| Polychlorinated Biphenyls (PCBs) - Total | 3 | 0.04 <MDL | |
| Benzo(a)pyrene | 0.01 | 0.004 <MDL | |
| Alachlor | 5 | 0.02 <MDL | |
| Atrazine + N-dealkylated metabolites | 5 | 0.01 <MDL | |
| Atrazine | - | 0.01 <MDL | |
| Desethyl atrazine | - | 0.01 <MDL | |
| Azinphos-methyl | 20 | 0.05 <MDL | |
| Carbaryl | 90 | 0.05 <MDL | |
| Carbofuran | 90 | 0.01 <MDL | |
| Chlorpyrifos | 90 | 0.02 <MDL | |
| Diazinon | 20 | 0.02 <MDL | |

Table 4 – Colborne DWS Schedule 13, 23 and 24 Sampling

| PARAMETER | STANDARD (µg/L) | SAMPLE RESULT (µg/L) | SAMPLE DATE |
|--|--------------------|-------------------------|-------------|
| Dimethoate | 20 | 0.06 <MDL | |
| Diuron | 150 | 0.03 <MDL | |
| Malathion | 190 | 0.02 <MDL | |
| Metolachlor | 50 | 0.01 <MDL | |
| Metribuzin | 80 | 0.02 <MDL | |
| Phorate | 2 | 0.01 <MDL | |
| Prometryne | 1 | 0.03 <MDL | |
| Simazine | 10 | 0.01 <MDL | |
| Terbufos | 1 | 0.01 <MDL | |
| Triallate | 230 | 0.01 <MDL | |
| Trifluralin | 45 | 0.02 <MDL | |
| 2,4-dichlorophenoxyacetic acid (24,-D) | 100 | 0.19 <MDL | |
| Bromoxynil | 5 | 0.033 <MDL | |
| Dicamba | 120 | 0.2 <MDL | |
| Diclofop-methyl | 9 | 0.4 <MDL | |
| MCPA | 0.1 | 0.00012 <MDL | |
| Picloram | 190 | 1 <MDL | |
| 2,4-dichlorophenol | 900 | 0.15 <MDL | |
| 2,4,6-trichlorophenol | 5 | 0.25 <MDL | |
| 2,3,4,6-tetrachlorophenol | 100 | 0.2 <MDL | |
| Pentachlorophenol | 60 | 0.15 <MDL | |
| Fluoride | 1.5 | 0.06 <MDL | 15-Apr-24 |
| Sodium | 20 | 7.41 | 15-Apr-24 |
| THM: Annual Average | 100 | 4.45 | 15-Oct-24 |
| HAA: Annual Average | 80 | 5.3 < MDL | |
| Nitrite | 1 | < 0.003 MDL | |
| Nitrate | 10 | 1.63 | |